

## 2023 Consumer Confidence Report

### Water System Information

Water System Name: **City of Fort Bragg CA**

Report Date: **May 19, 2024**

Type of Water Source(s) in Use: **Surface Water**

Name and General Location of Source(s): **Noyo River, located at the bottom of Madsen Lane. Newman Gulch, at the end of Summers Lane. Waterfall Gulch, on Franklin Road off of Simpson Lane.**

Drinking Water Source Assessment Information: **A Sanitary Survey was conducted in 2019 and is available upon request**

Time and Place of Regularly Scheduled Board Meetings for Public Participation: **Second and Fourth Mondays of the month at Town Hall at 6:00 PM**

For More Information, Contact: **Heath Daniels. Phone: (707) 961-4141 Email: hdaniels@fortbragg.com**

### About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2023 and may include earlier monitoring data.

### Importance of This Report Statement in Spanish

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse City of Fort Bragg a 416 N Franklin St. Fort Bragg CA, 95437 (707) 961-2823 para asistirlo en español.

### Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Term	Definition
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variations and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

## Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants that can be naturally-occurring or be the result of oil and gas production and mining activities.

## Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

### About Your Drinking Water Quality

#### Drinking Water Contaminants Detected

Tables 1, 2, 3, and 4 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

#### Table 1. Sampling Results Showing the Detection of Lead and Copper.

Lead and Copper	Sample Date	No. of Samples Collected	90 <sup>th</sup> Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	9/22/2021	20	<5.0	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	9/22/2021	20	0.180	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**Table 2. Sampling Results for Sodium and Hardness**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	11/28/23	12	12	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	11/28/23	47	47	60-120	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Table 3. Detection of Contaminants with a Primary Drinking Water Standard**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Turbidity (NTU)	11/28/23	0.7	0.7	5	N/A	Soil runoff
Halocetic Acids (ppb)	3/7,6/13,9/13,12/11/2023	27	1.6-41	60	N/A	Byproduct of drinking water disinfection
TTHMs Total Trihalomethanes (ppb)	3/7,6/13,9/13,12/11/2023	40.25	24-58	80	N/A	Byproduct of drinking water disinfection
Aluminum (mg/L)	11/28/23	0.062	0.062	1	0.6	Erosion of natural deposits; residue from some surface water treatment processes
Chromium (µ/L)	11/28/23	2.7	2.7	5	0.04	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride (mg/L)	11/28/23	0.15	.15	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories

**Table 4. Detection of Contaminants with a Secondary Drinking Water Standard**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (mg/l)	11/28/23	13	13	500	N/A	Erosion of natural deposits, residue from some surface water treatment process
Odor Threshold (TON)	11/28/23	6*	6	3	N/A	Naturally-occurring organic materials
Total Dissolved Solids (TDS) (ppm)	11/28/23	100	100	500	N/A	Runoff/leaching from natural deposits

Specific Conductance (µ/cm)	11/28/23	140	140	900	N/A	Substances that form ions when in water, sea water influence
Sulfate (mg/l)	11/28/23	5	5	500	N/A	Runoff/leaching from natural deposits, industrial wastes
Color (CU)	11/28/23	15*	15	15	N/A	Naturally occurring organic materials
Turbidity (NTU)	11/28/23	0.7	0.7	5.0	N/A	Soil runoff
Aluminum (mg/L)	11/28/23	.0027	.0027	0.2	N/A	Erosion of natural deposits; residual from some surface water treatment processes
Iron (mg/L)	11/28/23	0.16	0.16	0.3	N/A	Leaching from natural deposits; industrial wastes
Sulfate (mg/L)	11/28/23	5	5	500	N/A	Runoff/leaching from natural deposits; industrial wastes

**Color MCL Violation:** Color was found to match the Secondary MCL of 15 Units. Color is found in the water due to naturally occurring organic materials and has no known health effects and is in place in order to provide a aesthetically pleasing water

**Odor MCL Violation:** The Odor Threshold was found to exceed the Secondary MCL of 3. Odor is present in water due to naturally occurring organic materials and has no know health effects, and is in place to provide a pleasant water to drink

### Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA’s Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Fort Bragg is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

### For Systems Providing Surface Water as a Source of Drinking Water

**Table 5. Sampling Results Showing Treatment of Surface Water Sources**

Treatment Technique <sup>(a)</sup> (Type of approved filtration technology used)	Alternative
Turbidity Performance Standards <sup>(b)</sup> (that must be met through the water treatment process)	Turbidity of the filtered water must: 1 – Be less than or equal to 0.200 NTU in 95% of measurements in a month. 2 – Not exceed 0.200 NTU for more than eight consecutive hours. 3 – Not exceed 1.00 NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	99.9
Highest single turbidity measurement during the year	0.549
Number of violations of any surface water treatment requirements	0

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.